



# Pool Safety Checks

POOL FENCE	YES	NO
Is your pool fence is in good condition- no holes or broken areas?		
Are the gaps between the fence rails less than 100mm?		
Is the distance between the bottom of the pool fence and the ground less than 100mm?		
Is the height of your fence at least 1.2 metres high?		
Is your pool fence at lease 900mm away from any climbable structure e.g. trees and garden furniture.		

GATE	YES	NO
Is your gate self-closing and latching?		
Does your gate open outwards?		
Is the release mechanism shielded?		
If your gate latch is outside the gate is it at least 1.5m above ground level?		
If your gate latch is inside the gate, is it shielded or 150mm below the top of the gate so that a child cannot open the gate and at least 1.2m above ground level?		

SURROUNDING AREA	YES	NO
Is there a compliant resuscitation (CPR) sign prominently displayed on the pool fence?		
Is there a 900mm 'clear area' around the outside of your fence?		
Is there a 300mm 'clear area' around the inside of your fence?		